



भारतीय राजमार्ग अभियन्ता अकादमी  
(सड़क परिवहन एवं राजमार्ग मंत्रालय, भारत सरकार)  
**Indian Academy of Highway Engineers**  
(Ministry of Road Transport and Highways, Govt. of India)

F. No. F.237/2010-11/IAHE-Part(1)


Date: 13.03.2019

To,

All Perspective Bidders

Subject: Reply to the queries raised during pre bid conference by the perspective bidders for the work of “*Structural Repair of Exterior Damaged Components & Waterproofing Solutions to Terrace of Main Office Building of Indian Academy of Highway Engineers (IAHE) Noida*”

The pre bid conference was held on 12.03.2019 at 3.00 PM in the chamber of Additional Director, IAHE Noida for the subject work mentioned above as per schedule mentioned in RFP. It was observed that representative attended the pre conference without authorisation letter to attend the same. Accordingly, it was requested to furnish the written queries. The para wise reply to the written queries is enclosed herewith for kind information and perusal.

  
(Devender Kumar)  
Deputy Director  
For Director, IAHE

Reply to the queries raised during pre bid conference held on 12.03.2019 in the chamber of Additional Director, IAHE Noida for the work of "Structural Repair of Exterior Damaged Components & Waterproofing Solutions to Terrace of Main Office Building of Indian Academy of Highway Engineers (IAHE) Noida"

Sl. No.	Name of bidder	Queries of perspective bidders	Reply of IAHE
1	M/s Saptagiri Constriction(Engineers and Contractors)	Being a MSME registered vendor for services, can we avail the Tender fee & EMO waiver for the above tender?	As per RFP
2		You have specified to submit Authorisation letter of Chemical Product mentioned in Specifications viz Fosroc/Sikka / Equivalent. Though we have used the Fosroc/Sikka products in various similar works & with reputed Clients NTPC, IFFCO etc, we have the certificate issued by Equivalent Manufacturer M/s Krishna Conchem Products Pvt.ltd, whose chemical products are approved in CPWD/ NTPC/ EII/ and other Government & PSU'S and are being used by us for past several years. Hence can we submit M/s KCPL Certificate issued to us for Technical Qualification and accordingly use M/s KCPL Products as equivalent product? (A copy of Certificate issued by M/s KCPL is enclosed as attachment).	As per RFP
3	M/s SSA TECHNO CONSTRUCTION PVT. LTD.	As per tender clause, bidder needs to submit authorized applicator letter issued by manufacture. Can we submit more than one authorized applicator letter?	As per RFP

Sl. No.	Name of bidder	Queries of perspective bidders	Reply of IAHE
4		Unit of BOQ Item no. 18 should be in 'sqm' instead of 'cum'.	Yes, The unit shall be Sqm.
5		Unit of BOQ Item no. 19 is not mentioned. It should be in 'sqm'	Yes, The unit shall be Sqm.
6		As per work methodology for terrace waterproofing (tiling roof), contractor need to dismantle/ remove tiling from the terrace. After dismantling, whether existing tiles will be re-fix or not.	No, after dismantling, existing tiles would not be used and provision of Kota stone has been mentioned in item no. 21
7		Is it required to do repairing from inside of auditorium or any other block?	No. Only Exterior components are included in the scope of the work.